



**North Western Railway
Central Hospital, Jaipur**



Sample Id : 2022/09/07/0037
Date : 07/09/2022
Mode : Human

Patient Id : 2022Sep07-C.SCHOOL
Name : WATER COOLER PHULERA
C.SCHOOL WATER COOLER
AGE: PHULERA
Gender : -



Test	Conc.	Unit	Ref. Range
Test Name : WATER CULTURE TEST FOR COLIFORM			
Specimen	--	Water	
Station	--	Central School Water Cooler Phulera	
Result	--	0	MPN/100ml
Interpretation	--	LOW RISK/ SAFE	

NOTE:

HEALTH RISK BASED ON 2011 WHO GUIDELINES FOR DRINKING WATER QUALITY

CATEGORY	E.coli CFU* PER 100 ml
Low risk/ Safe	0
Intermediate risk/Probably Safe	1-9
High risk/Probably Unsafe	10-99
Very high risk/ Unsafe	>100

*CFU: Colony forming units(CFU) & Most probable number (MPN) are equivalent, CFU is obtained in colony based tests while MPN is obtained in quantal tests.

To,

The President,
School Management Committee,
Kendriya Vidyalaya Samiti, Phulera.

Date
09/09/22

Sub:→ Health, Sanitation and Safe drinking
Water certificate.

Ref. No.→ 08/KVFL/2022-23/229. . Dt. 05.09.2022.

This is to certify that proper health
and sanitation conditions prevail at K.V
Phulera and safe drinking water facilities
are available in Vidyalaya.

Enclosed → Water sample Report

↓
Rajni
09/09/22

मुख्य स्वास्थ्य निरीक्षक
Chief Health Inspector
स.प. देवे, फुलेरा
K. V. N. V. PHULERA

अपर मुख्य चिकित्सा अधीक्षक
Add. Chief Medical Supdt
स्वास्थ्य इकाई फुलेरा
Health Unit Phulera